



DPS | Montgomery County
Department of Permitting Services



2425 Reedie Drive, 7th Floor
Wheaton, MD 20902
240-777-0311
montgomerycountymd.gov/dps

Residential Spa/HotTub Inspections

Inspection Sequence		Prior to Inspection Request		Performed by		Inspection approval required prior to
Type	Code	Work to be Completed	Approved Inspections	DPS	Others	
Trench, if applicable	104	1. Trench excavated to the required depth (Table 300.5 of the 2014 NEC). Site tubes only allowed if permission granted by inspector.		Yes		• Backfilling trench
Final	251	1. Unit to be set and ready for use. 2. If heated shall have a vapor-retardant cover. 3. All wiring per 2014 NEC section 680.	• Electrical 104, if applicable	Yes		• Using unit