



GENERAL NOTES

1. THIS STANDARD TO BE USED WITH CURB RADIUS LESS THAN 30'.
2. REFER TO MARYLAND STATE HIGHWAY ADMINISTRATION SPECIFICATIONS FOR MATERIAL AND METHODS OF CONSTRUCTION.
3. SIDEWALK RAMPS SHOULD BE LOCATED AS INDICATED, HOWEVER, EXISTING SURFACE UTILITIES MAY AFFECT PLACEMENT.
4. EXPANSION JOINT MATERIAL SHALL BE 1/2 INCH PREFORMED CORK, TRIMMED AND SEALED WITH NON-STAINING, TWO COMPONENT POLYSULFIDE OR POLYURETHANE ELASTOMERIC TYPE SEALANT, COMPLYING WITH ASTM-C920.



APPROVED 14 APR 06  
DATE

*Auth. [Signature]*  
DIRECTOR, DEPT. OF PUBLIC  
WORKS & TRANSPORTATION

*Holger [Signature]*  
for CHIEF, DIV. OF CAP. DEV.

REVISED

ASTM-C920 4/2006

MONTGOMERY COUNTY  
DEPARTMENT OF PUBLIC WORKS & TRANSPORTATION

BUSINESS DISTRICT SIDEWALK  
DUAL RAMP

STANDARD NO. MC-113.02