

BUREAU OF LIFE SAFETY SERVICES
OFFICE OF FIRE CODE ENFORCEMENT
ADMINISTRATIVE INTERPRETATION 00-1

CODE REFERENCE : Montgomery County Fire Safety Code 22-29

BACKGROUND:

This section of the code requires that the water supply for buildings other than one and two family dwellings must be provided with fire hydrants connected to a water supply capable of supplying the water flow required by the administrator.

INTERPRETATION:

That the hydrant closest to the property must be capable of delivering a minimum of 1000 gallons per minute with 20 psi residual pressure. The next closest hydrant must be capable of flowing a minimum of 500 gallons per minute at the same time.

PREPARED BY:

Captain James A. Barton

DATE: January 6, 2000

FIRE MARSHAL

A handwritten signature in cursive script, appearing to read "Richard Jarboe", is written over a horizontal line.