



Q4 2023 DA FIG Report for GenOn Holdings LLC., Dickerson Facilities

Combustion Turbine Site (Dickerson Power, LLC.)

- Safety concerns for the period – **None**
- Environmental concerns for the period – **One**
 - On 01Nov H2CT was forced offline due to a hydraulic oil hose failure. Approximately 30 gallons were contained within the unit area. The hose was replaced, and all material was cleaned. The extent of condition was reviewed on both units and replacements made where deficiencies were noted.
- No operational issues to report since the last review.
 - 302 starts / 2462 Service Hours YTD (Nov) 2023
 - 174 starts / 1012 Service Hours in 2022 (both <2021)
- GenOn Holdings, LLC. transfer of Lanyard Power, LLC. (parent of Dickerson and Chalk Point Power, LLC's) to Olympus Power will occur in December, pending FERC approval. Lanyard Power employees will become CAMS employees 1/1/2024. Maryland Ash Management, LLC will remain with GenOn. Oversight of Westland going forward will be with Steve Frank, Sr. Environmental Manager, and Jay Spence, Ash Site Superintendent.

Westland Ash Landfill (Maryland Ash Management, LLC.)

- Safety concerns for the period – **None**
- Environmental concerns for the period – **None**
- No operational issues during the period
 - Processed and discharged 3,490,200 gal thru the WWTP YTD (Nov)
- Ash mining activities.
 - 187,690 tons of Fly Ash removed thru YTD (Nov)
 - 692,127 tons of Fly Ash removed since the project started.

Mike Bennett

Plant Manager

Lanyard Power, LLC.

Chalk Point & Dickerson Stations

C - 240.372.3049

O - 301.601.6522

David.Bennett@GenOn.com