



DEPARTMENT OF PERMITTING SERVICES

Isiah Leggett
County Executive

Diane R. Schwartz Jones
Director

May 10, 2016

Dept Gen Services
Div of Bida Desgn & Const

MAY 16 2016

RECEIVED

Mr. Michael Kay
Montgomery County Dept. of General Services
101 Monroe Street, 11th Floor
Rockville, Maryland 20850

Re: Preliminary/Final Water Quality Plan
Reconfirmation for Clarksburg Fire Station #35
SWM Concept #239636

Dear Mr. Kay:

Your request for a stormwater management reconfirmation for the above site has been evaluated. The original approved Preliminary/Final Water Quality Plan dated 7/29/2011 is hereby reconfirmed. Please adhere to all conditions required as part of that approval.

This reconfirmation includes a reduction in impervious area and no change in the stormwater management design (micro biofilters and a structural filter to treat the fueling area before outfalling to a micro biofilter).

If you have any questions regarding these actions, please feel free to contact Leo Galanko at 240-777-6242.

Sincerely,

Mark C. Etheridge, Manager
Water Resources Section
Division of Land Development Services

Cc: C. Conlon
SM File #: 239636

ESD Acres: 4.04
Structural Acres: 0.20
Waived Acres: 0