



GENERAL NOTES

1. STEPS ARE TO BE MADE OF: (1) CAST IRON, 1 INCH SQUARE ; (2) 3/8 INCH STEEL ROD EMBEDDED IN POLYPROPYLENE PLASTIC ; OR (3) ALUMINUM ALLOY, 7/8 INCH BY 13/16 INCH WITH A MINIMUM EMBEDMENT OF 3 INCHES, A MINIMUM PROJECTION OF 5 INCHES, AND A MINIMUM WIDTH OF 10 INCHES.
2. STEPS SHALL BE PLACED IN VERTICAL ALIGNMENT, 12 INCHES APART, AND SHALL ALIGN WITH THE COVER OPENING.
3. STEPS ARE NOT REQUIRED IN STRUCTURES LESS THAN 4 FEET IN DEPTH.

P:\DDTSTD\STD55A 6-24-94 110:37 pm EST

APPROVED <u>JAN 5 / 95</u> DATE	REVISED <hr/> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/>	MONTGOMERY COUNTY DEPARTMENT OF TRANSPORTATION
 DIRECTOR, DEPT. OF TRANS.		MANHOLE AND INLET STEPS
 CHIEF, DIV. OF ENG. SERVICES		STANDARD NO. MC-520.01