

9. The fuel/power source of all hazards being protected shall be clearly stated on the plans.

D. **EQUIPMENT**- To be uploaded into the Documents folder of ePlans

1. Include catalog cuts for all equipment to be used which evidence the listing of the equipment.
2. For system additions, submit existing equipment catalog cuts for coordination and to check compatibility.
3. Annotate all catalog cuts to show exact model(s) to be used.

F. **SEQUENCE OF OPERATIONS-**

1. A sequence of operations shall be provided for each system. Where multiple hoods and/or systems are present information shall be provided regarding if systems operate simultaneously or individually. Where fire alarm systems are present in the building, the system is required to be connected to the building fire alarm system which requires a fire alarm permit from DPS