



2425 Reedie Drive, 7th Floor
Wheaton, MD 20902
montgomerycountymd.gov/dps
240-777-0311

COLD WEATHER HYDROSTATIC TEST CERTIFICATION

ADDRESS: _____

DATE: _____ **TIME:** _____ **A/P #** _____

This document certifies that the sprinkler contractor has filled the entire sprinkler system with water and pressurized the sprinkler piping to _____ psi for 2 hours during which, the complete sprinkler system has been visually checked for leaks/breaks at each joint, coupling, and piping throughout the structure. Any leaks or breaks have been corrected before concealment of the sprinkler system piping.

THE SIGNATURES BELOW EVIDENCE THAT THE GENERAL CONTRACTOR AND THE SPRINKLER CONTRACTOR UNDERSTAND, AND THE GENERAL CONTRACTOR CERTIFY AND AFFIRM THAT THEY HAVE WITNESSED THE HYDROSTATIC TESTING OF THE SPRINKLER SYSTEM AS STATED ABOVE AND ARE IN COMPLIANCE WITH ALL SPECIFICATIONS LISTED HEREIN.

SIGN _____
Sprinkler Contractor Signature

SIGN _____
General Contractor Signature

PRINT _____
Sprinkler Contractor Printed Name

PRINT _____
General Contractor Printed Name

IMPORTANT

*By signing this document the General and Sprinkler Contractors acknowledge that this home will again have the sprinkler system pressurized to test pressure at time of final inspection and it must be *witnessed by the fire marshal.**
12/07/2020