



DPS | Montgomery County
Department of Permitting Services



2425 Reedie Drive, 7th Floor
Wheaton, MD 20902
240-777-0311
montgomerycountymd.gov/dps

Residential Photovoltaic (Solar) Inspections

Rooftop Panels

Inspection Sequence		Prior to Inspection Request		Performed by		Inspection approval required prior to
Type	Code	Work to be Completed	Approved Inspections	DPS	Others	
Final	251	<ol style="list-style-type: none"> 1. All components of the solar project installed. 2. All connections to the grid (if applicable) must be completed. (Installation in accordance with NEC Section 690) 3. Packet including plans and pictures of the installation to be provided to the inspector at the time of inspection 	<ul style="list-style-type: none"> • Building 001, if ground mount • Electrical 104 (trench inspection, if ground mount) 	Yes		<ul style="list-style-type: none"> • Energizing