
PROP. STORMWATER MANAGEMENT FACIL

DISTURBANCE

MICRO-BIORETENTION #1

SCALE: 1" = 20'



The state of the s	STANDARD SYMBOL
DETAIL D-4-1-A ROCK OUTLET PROTECTION	
L	KOPT
B - A B-	DISCHARGE TO SEMI CONFINED CHANNEL SECTION
	SECTION A-A CHANNEL CROSS SECTION WILL
	TRANSITION FROM A-A TO B-B
PLAN VIEW 4	IN W
EXTEND RIPRAP TO A MIN. HEIGHT OF H BY CHANNEL SECTION AT END OF APRON GEOTEXTILI STONE FIL	E OR /
0% 14 IN	SECTION B-B
NONWOVEN SLOPE TO DRAIN	RIPRAP
GEOTEXTILE OR /I_L_6 IN 3 FT MIN.	CLASS THICKNESS (T)
STONE FILTER - L12 IN MIN.	I 19 IN
PROFILE	II 32 IN
CONSTRUCTION SPECIFICATIONS	III 46 IN

- RIPRAP AND STONE MUST CONFORM TO THE SPECIFIED CLASS.
- 2. USE NONWOVEN GEOTEXTILE AS SPECIFIED IN SECTION H-1 MATERIALS, AND PROTECT FROM PUNCTURING, CUTTING, OR TEARING. REPAIR ANY DAMAGE OTHER THAN AN OCCASIONAL SMALL HOLE BY PLACING ANOTHER PIECE OF GEOTEXTILE OVER THE DAMAGED PART OR BY COMPLETELY REPLACING THE GEOTEXTILE. PROVIDE A MINIMUM OF ONE FOOT OVERLAP FOR ALL REPAIRS AND FOR JOINING TWO PIECES OF GEOTEXTILE TOGETHER.
- PREPARE THE SUBGRADE FOR GEOTEXTILE OR STONE FILTER (% TO 11/2 INCH STONE FOR 6 INCH MINIMUM DEPTH) AND RIPRAP TO THE REQUIRED LINES AND GRADES. COMPACT ANY FILL REQUIRED IN THE SUBGRADE TO A DENSITY OF APPROXIMATELY THAT OF THE SURROUNDING UNDISTURBED MATERIAL
- EXTEND GEOTEXTILE AT LEAST 6 INCHES BEYOND EDGES OF RIPRAP AND EMBED AT LEAST 4 INCHES AT SIDES OF THE RIPRAP.
- 6. CONSTRUCT RIPRAP OUTLET TO FULL COURSE THICKNESS IN ONE OPERATION AND IN SUCH A MANNER AS TO AVOID DISPLACEMENT OF UNDERLYING MATERIALS. PLACE STONE FOR RIPRAP OUTLET IN A MANNER THAT WILL ENSURE THAT IT IS REASONABLY HOMOGENOUS WITH THE SMALLER STONES AND SPALLS FILLING THE VOIDS BETWEEN THE LARGER STONES. PLACE RIPRAP IN A MANNER TO PREVENT DAMAGE TO THE STONE FILTER BLANKET OR GEOTEXTILE. HAND PLACE TO THE EXTENT NECESSARY.
- WHERE NO ENDWALL IS USED, CONSTRUCT THE UPSTREAM END OF THE APRON SO THAT THE WIDTH IS TWO TIMES THE DIAMETER OF THE OUTLET PIPE, AND EXTEND THE STONE UNDER THE OUTLET BY A MINIMUM OF 18 INCHES.
- CONSTRUCT APRON WITH 0% SLOPE ALONG ITS LENGTH AND WITHOUT OBSTRUCTIONS. PLACE STONE SO THAT IT BLENDS IN WITH EXISTING GROUND.
- MAINTAIN LINE, GRADE, AND CROSS SECTION. KEEP OUTLET FREE OF EROSION. REMOVE ACCUMULATED SEDIMENT AND DEBRIS. AFTER HIGH FLOWS INSPECT FOR SCOUR AND DISLODGED RIPRAP. MAKE NECESSARY REPAIRS IMMEDIATELY.

NECESSART REPAIRS IMMEDIATELT.		
MARYLAND STANDARDS AND SPE	CIFICATIONS FOR SOIL ER	ROSION AND SEDIMENT CONTROL
U.S. DEPARTMENT OF AGRICULTURE NATURAL RESOURCES CONSERVATION SERVICE	2011	MARYLAND DEPARTMENT OF ENVIRONMENT WATER MANAGEMENT ADMINISTRATION

Calculating the PE for the site					
Site Area		3,664,828	SF	84.13	A
Impervious Area		12,809	SF	0.29	A
Pervious Are	a	3,652,019	SF	83.84	A
Site Imperviousne	ess (I)	0.003		0.3%	
PE(IN)	1.0	This value is tal	cen fr	om Table 5.3 in	
r = (//V)	1.0	Chapter 5 of the	MDI	∃ Manual	

Disturbed Are	ea	32,265	SF	0.74	AC
Impervious Ar	rea	7,537	SF	0.17	AC
Pervious Are	a	24,728	SF	0.57	AC
Site Imperviousne	ess (I)	0.234		23%	
	SF	AC]		

PE	1.0	inches	Rv = 0.05 + 0.009*1
Rv	0.260		
Α	32,265	SF	$ESDv = \frac{(Pe)(Rv)}{}$
ESDv Required	700	CF	12

Summary Table	
Required ESDv	700
Provided ESDv from MBF #1	817
Total Provided ESDv	817
Required Pe	1.00
Provided Pe	1.17

SWM #1	Micro-Bioretention		
ESDv MAX	918	CF	
PE	2.6	inches	
Rv	0.260		
A	16,309	SF	
ESDv MIN	353	CF	
PE	1.0	inches	
Rv	0.260		
A	16,309	SF	

 $ESDv Max/Min = \frac{(Pe)(Rv)(A)}{12}$

ESDv Provided	817	CF	
	(467*0.75) + [0.4*(467*2.5)]	
ESDv	x (Area of Facility x Media Layer)		
	(Area of Facility x Ponding Depth) + (Poros		
Media Layer	2.5	feet	
•	101	<u> </u>	
Size of Facility	467	SF	
Ponding Depth	9	inches	

Imperviousnes	s (I)	
Impervious Area to Facility	3,800	SF
Total Area to Facility	16,309	SF
Imperviousness	23%	

Rv = 0.05 + 0.009

edia Layer	2.5	feet
lanting Media	2	feet
and	0.5	feet

Calculating the	Required E	SDv for t	he sit	ie	
Disturbed Area		32,265	SF	0.74	A
Impervious Area		7,537	SF	0.17	Α
Pervious Area		24,728	SF	0.57	Α
Site Imperviousness (I)		0.234		23%	
			_		
SF	,	AC			

	SF	AC
Total Parcel Area =	4,770,691	109.52
Site Area (LOD) =	280,793	6.45
Disturbed Access Area =	32,265	SF
Disturbed Solar Area =	ī	SF
Disturbed Area =	32,265	0.74

ESDv Required	700	CF	12
A	32,265	SF	$ESDv = \frac{(Pe)(Rv)}{(Pe)(Rv)}$
Rv	0.260		
PE	1.0	inches	Rv = 0.05 + 0.009*1

SVV IVI #1	Micro-Bioretention		
	,		
ESDv MAX	918	CF	
PE	2.6	inches	
Rv	0.260		
A	16,309	SF	
ESDv MIN	353	CF	
PE	1.0	inches	
Rv	0.260		
A	16,309	SF	

ESDv	= Ponding Depth + Storage in Filter Medi
	$(D_a)(D_{aa})(A)$

Ponding Depth	9	inches
Size of Facility	467	SF
Media Layer	2.5	feet
	(Area of Facility x Ponding Depth) + (Porosit	
ESDv	x (Area of Facility x Media Layer)	
	(467*0.75) + [0.4*(467*2.5)]	
ESDv Provided	817	CF
ESDv Max Allowed	918	CF

Imperviousness (I)		
Impervious Area to Facility	3,800	SF
Total Area to Facility	16,309	SF
Imperviousness	23%	

SWM #295856

MOUNT

JNTAIN VALE

JNTAIN VALE

17700 BARNESVILLE

WSSC GRID #230NW17, 2

TAX MAP: CV62, GF

RY COUNTY, MARYLAND



05/06/25

PLAN STATUS			
	1ST SUBMISSION		
4/28/25	2ND SUBMISSION		
5/06/25	3RD SUBMISSION		

DATE	DESCRIPTION	
EP	CD	EP
DESIGN	DRAWN	CHKD
SCALE	H: 1"=20 V: N/A)'

JOB No. 140362-01-001 DATE: APRIL, 2025

FILE No. SMCO0008

SHEET SWM 08 OF 8

CAUTION!!

THE LOCATIONS OF ALL EXISTING UNDERGROUND UTILITIES SHOWN ON THIS PLAN ARE BASED UPON ABOVE GROUND EVIDENCE (INCLUDING, BUT NOT LIMITED TO, MANHOLES, INLETS, VALVES, AND MARKS MADE UPON THE GROUND BY OTHERS) AND ARE SPECULATIVE IN NATURE. THERE MAY ALSO BE OTHER EXISTING UNDERGROUND UTILITIES FOR WHICH THERE IS NO ABOVE GROUND EVIDENCE OR FOR WHICH NO ABOVE GROUND EVIDENCE WAS OBSERVED. THE EXACT LOCATIONS OF SAID EXISTING UNDERGROUND UTILITIES SHALL BE VERIFIED BY THE CONTRACTOR PRIOR TO ANY AND ALL CONSTRUCTION.

Call "MISS UTILITY" at 1-800-257-7777, 48 hours prior to the start of work.

The excavator must notify all public utility companies with underground facilities in the area of proposed excavation and have those facilities located by the utility companies prior to commencing excavation. The excavator is responsible for compliance with requirements of Chapter 36A of the Montgomery County Code.