

Subject: RE: Request for Comments on ROW Abandonment (AB 770 - Kensington Boulevard)
Date: Monday, March 30, 2020 at 9:11:26 AM Eastern Daylight Time
From: Warnick, Pastora
To: McCray, Tiara
Attachments: Abandonment Area Map.pdf, image001.png, hydrant kens.PNG

Good morning Tiara,

Our only comment is that the "T" where Kensington Blvd intersects with East Ave is required for fire department apparatus turn around, for 60 feet in each direction of the intersection. It is our opinion that the intersection (for full curb to curb width and for at 60 feet in each direction of the intersection) must remain ROW for fire department operations. Feel free to contact me if you have any questions or concerns.

Regards,

Patsy Warnick, PE, CSP
Manager, Fire Code Compliance

Office of the Fire Marshal
Department of Permitting Services

(o) 240-773-8906 (c) 240-642-8208
www.montgomerycountymd.gov/dps

DPS – COVID-19 UPDATE

Effective Monday, March 23 - DPS Offices are closed to the public. DPS continues to deliver services with modifications. For information about electronic plan submittal and inspection scheduling, please visit the DPS website www.montgomerycountymd.gov/dps. Thank you for your patience.

From: McCray, Tiara <Tiara.McCray@montgomerycountymd.gov>
Sent: Thursday, March 26, 2020 1:46 PM
To: Warnick, Pastora <Pastora.Warnick@montgomerycountymd.gov>
Subject: Fw: Request for Comments on ROW Abandonment (AB 770 - Kensington Boulevard)

Good afternoon Patsy,

Thank you again for helping me with this matter. Please see below the request for comments that were submitted to all agencies affected. The comment does not have to be on formal letterhead, as many people simply respond via email. However, we are more than happy to accept your comment in any form.

Please let me know if you have any questions or concerns.

Kind regards,

Tiara McCray

From: McCray, Tiara

