

囟

MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

| Subject Fire Lane Establishment Order for Farmland Elementary School | Executive Order No. 81-17 | Subject Suffix |
|---|----------------------------------|------------------------------|
| Originating Department Montgomery County Department of Permitting Services | Department Number MCDPS 12-17 | Effective Date 05/09/2017 |

Fire Lane Establishment Order


Pursuant to Section 22 - 33, Montgomery County Code, 1971, as amended, you are hereby notified that a Fire Lane has been established as described in this order. You are hereby ordered to post fire lane signs and paint curbs/pavement (painting optional) as identified below. When signs and paint work (painting optional) have been completed, this order will authorize the enforcement of this Fire Lane by appropriate police and fire officials. Compliance with this order must be achieved within 30 days of receipt.

readable by motor vehicle operators.

| f this Fire Lane | ainting optional) have been completed, this order will author appropriate police and fire officials. Compliance with the days of receipt. |
|-------------------|---|
| LOCATION: | 7000 Old Gate Rd. |
| - - | |
| All are | s where indicated by signs and paint. |
| SIGNS (See | attached diagram for location of sign placement) |
| \$250 FINE | Signs must be posted so that it is not possible to park a vehicle without being |
| FIRE LAN | in sight of a sign. Signs may be no further apart than 100 feet |
| (Red letters on | white background) |
| <u>PAINT</u> (See | attached diagram if painting). |
| | Paint must be traffic yellow with lines of |


Fire Marshal, Montgomery County Department of Permitting Services

Revised 4/96



VICINITY MAP

SCALE: 1"=1000'



S1





FIRE LANE SIGNS

GENERAL NOTES:

- SIGNS TO BE CONSISTENT WITH THE MONTGOMERY COUNTY FIRE AND RESCUE (MCFR) GUIDELINES
- 2. FIRE LANE SIGNS TO BE 12" WIDE BY 18" HIGH




Engineering a Sustainable Future Nobis Engineering, Inc. 20410 Century Blvd Suite 230 Germantown, MD 20874 T(301) 528-2010

www.nobiseng.com Client - Focused, Employee - Owned FARMLAND ELEMENTARY SCHOOL 7000 OLD GATE ROAD ROCKVILLE, MARYLAND 20852

FIRE LANE ACCESS PLAN

JOB NO.: 86980.67 SHEET NO: SCALE: 1"=2000' DATE: MAY 2017 1 OF 2



FIRE LANE PLAN 1"=100'

<u>LEGEND</u>

• FIRE LANE SIGN (TYP)



Engineering a Sustainable Future
Nobis Engineering, Inc.
20410 Century Blvd Suite 230
Germantown, MD 20874
T(301) 528-2010
www.nobiseng.com
Client - Focused, Employee - Owned

FARMLAND ELEMENTARY SCHOOL 7000 OLD GATE ROAD ROCKVILLE, MARYLAND 20852 FIRE LANE ACCESS PLAN

JOB NO.: 86980.67 SHEET NO: 2 OF 2