



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 123-19	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 02-19	Effective Date 6/23/19

Re: Acceptance of Roads for Maintenance MCDPS Permit No., 301533.

This is to certify that construction of the following named street has been completed in accordance with all applicable provisions of the Montgomery County Road Design and Construction Code as specified in the above-referenced permits. The materials used in the construction of the street were tested and found to be in compliance with County Standards and Specifications.

Subdivision: Cloverly Forest
Permit No.: 301533
Date of Final Inspection: 12/10/2018
Total Distance: 1,091 feet/0.21 miles
Total Lane Miles: 0.34
Total Bond Amount: \$277,400.00

Richmond American Homes of Maryland Inc.
6210 Old Dobbin Lane
Columbia, MD 21045

Rainbow Drive: A modified secondary open section roadway with a right of way 68 feet wide beginning 90 feet south of the intersection of Snider Lane at Station 25+48 and continuing in a southwesterly direction ending at Station 28+64.39 at the intersection of Cloverly Forest Drive for a distance of 316 feet. Paving width of 20 feet, with storm drainage, and sidewalk left side only. Pavement consists of a 5- inch asphaltic concrete base course, 1.5-inch asphaltic concrete intermediate course and a 1.5-inch asphaltic concrete surface course.

Cloverly Forest Drive: A modified tertiary open section roadway with a right of way 68 feet wide beginning at the center of a cul-de-sac at Station 0+00, 342 feet west of the intersection of Rainbow Drive at Station 3+41.80 and continuing in a southeasterly direction and including the intersection at Rainbow Drive (Station 3+41.80) and ending at Station 7+74.97 at center of a cul-de-sac for a distance of 775 feet. Paving width of 20 feet, with storm drainage, and sidewalk left side only. Pavement consists of a 3- inch asphaltic concrete base course, 1.5-inch asphaltic concrete intermediate course and a 1.5-inch asphaltic concrete surface course.



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 123-19	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 02-19	Effective Date 6/23/19

SUMMARY OF THIS EXECUTIVE ORDER

Number of Permits: 1
 Number of Subdivisions: 1
 Distance of Streets Accepted - Feet: 1,091
 Distance of Streets Accepted - Miles: 0.21
 Distance of Streets Accepted - Lane-Miles: 0.34

All work and submissions required for acceptance of the foregoing streets has been completed and acceptance is recommended.

June 11, 2019
Date

By: Christina T. Carter
Manager, Department of Permitting Services
Division of Land Development
Right-of-Way Inspections

It is recommended that Montgomery County, Maryland, accept the roads described above for maintenance:

Date

Charles M. ...
Acting Director, Department of Permitting Services

Said roads are hereby accepted for maintenance:

6/23/19
Date

Fawcett L. ...
Assistant Chief Administrative Officer
Deputy

APPROVED AS TO FORM AND LEGALITY
OFFICE OF THE COUNTY ATTORNEY
BY: Charles S. ...
DATE: 14 June 2019