



# MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 020-17	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 06-16	Effective Date 3/10/17

**Re: Acceptance of Roads for Maintenance MCDPS Permit Nos. 278829 and 305527.**

This is to certify that construction of the following named streets has been completed in accordance with all applicable provisions of the Montgomery County Road Design and Construction Code as specified in the above-referenced permits. The materials used in the construction of these streets were tested and found to be in compliance with County Standards and Specifications.

**Subdivision Name-Nehouse**  
**Subdivision/Piedmont Acres**  
**Permit No.: 278829**  
**Date of Final Inspection: June 30, 2015**  
**Total Distance: 534 feet/0.10 miles**  
**Total Lane Miles: 0.17**  
**Total Bond Amount: \$105,500.00**


**Stanley Enterprises**  
**P.O. Box 577**  
**Damascus, MD 20872**

**HAWKES LANE:** An open section tertiary residential road with a right-of-way of 50 feet wide starting at Station 0+00 at the intersection of Hawkes Road to Station 5+33.74. A distance of 534 feet, 20 feet wide pavement, with storm drainage and side ditches, with a 3 inch asphaltic base course, 1.5 inch asphaltic intermediate course, and a 1.5 inch asphaltic surface course.

**Subdivision Name-Multi-Agency Service Park**  
**Permit No.: 305527**  
**Date of Final Inspection: December 22, 2015**  
**Total Distance: 2,316 feet/0.44 miles**  
**Total Lane Miles: 0.88**  
**Total Bond Amount: County constructed**

**Montgomery County Department of General Services**  
**101 Monroe Street**  
**Rockville, MD 20850**

**TURKEY THICKET DRIVE:** An open section tertiary residential road with a variable width right-of-way beginning at Station 0+00 and continuing to Station 23+16.22 ending at a residential driveway. A distance of 2316 feet, paving width varies, sidewalks left side only five (5) feet in width, storm drainage, side ditches, an 8 inch graded aggregate base course, a 5-inch asphaltic concrete base course, a 1.5-inch asphaltic concrete intermediate course, and a 1.5-inch asphaltic concrete surface course.



# MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 020-17	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 06-16	Effective Date 3/10/17

### SUMMARY OF THIS EXECUTIVE ORDER

Number of Permits: .....2  
 Number of Subdivisions: .....2  
 Distance of Streets Accepted - Feet:.....2,850  
 Distance of Streets Accepted - Miles: .....0.54  
 Distance of Streets Accepted - Lane-Miles: ..... 1.05

All work and submissions required for acceptance of the foregoing streets has been completed and acceptance is recommended.

Nov 10, 2016  
Date

By: Christina T. Carter  
Manager, Department of Permitting Services  
Division of Land Development  
Right-of-Way Inspections

It is recommended that Montgomery County, Maryland, accept the roads described above for maintenance:

January 10, 2017  
Date

Diane A. Jones  
Director, Department of Permitting Services

Said roads are hereby accepted for maintenance:

3/10/17  
Date

Remona Bell-Pass  
Assistant Chief Administrative Officer

**APPROVED AS TO FORM AND LEGALITY  
OFFICE OF THE COUNTY ATTORNEY**  
BY: Charles J. Keefe  
DATE: 28 November 2016