

ProLaw # 18-008151



# MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 217-18	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 07-18	Effective Date 10/29/18

**Re: Acceptance of Roads for Maintenance MCDPS Permit No.,  
269770.**

This is to certify that construction of the following named streets has been completed in accordance with all applicable provisions of the Montgomery County Road Design and Construction Code as specified in the above-referenced permits. The materials used in the construction of these streets were tested and found to be in compliance with County Standards and Specifications.

**Subdivision: Eton Square**  
**Permit No.: 269770**  
**Date of Final Inspection: 4/2/2017**  
**Total Distance: 734 feet/0.14 miles**  
**Total Lane Miles: 0.42**  
**Total Bond Amount: \$124,500.00**

**Eton Square, LLC**  
**c/o Craftstar Homes**  
**6820 Elm Street, 2<sup>nd</sup> Floor**  
**McLean, VA 22101**

**Oxbridge Drive:** A primary closed section residential roadway with a right of way 70 feet wide beginning approximately 475 feet west of the intersection of Frederick Road (Maryland Route 355) at Station 4+75 and continuing in a westerly direction ending at Station 5+75 including the intersection of Cider Barrel Drive. A distance of 100 feet, 36 feet wide pavement, with curbs and gutters, storm drainage and sidewalks, 5 feet in width on both sides. Pavement consists of a 5- inch asphaltic concrete base course, 1.5-inch asphaltic concrete intermediate course and a 1.5-inch asphaltic concrete surface course.

**Cider Barrel Drive:** A primary closed section residential roadway with a right of way 70 feet wide beginning at Station 10+33, and continuing 634 feet north to the intersection of Oxbridge Drive at Station 16+67.22. A distance of 634 feet, 36 feet wide pavement, with curbs and gutters, storm drainage and sidewalks, 5 feet in width on both sides. Pavement consists of a 5- inch asphaltic concrete base course, 1.5-inch asphaltic concrete intermediate course and a 1.5-inch asphaltic concrete surface course.



# MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 217-18	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 07-18	Effective Date 10/29/18

### SUMMARY OF THIS EXECUTIVE ORDER

Number of Permits: ..... 1  
 Number of Subdivisions: ..... 1  
 Distance of Streets Accepted - Feet: ..... 734  
 Distance of Streets Accepted - Miles: ..... 0.14  
 Distance of Streets Accepted - Lane-Miles: ..... 0.42

All work and submissions required for acceptance of the foregoing streets has been completed and acceptance is recommended.

10/22/2018  
Date

By: Christina Crittens  
Manager, Department of Permitting Services  
Division of Land Development  
Right-of-Way Inspections

It is recommended that Montgomery County, Maryland, accept the roads described above for maintenance:

\_\_\_\_\_  
Date

Richard J. ...  
Director, Department of Permitting Services

Said roads are hereby accepted for maintenance:

10/29/18  
Date

Favala  
Assistant Chief Administrative Officer

APPROVED AS TO FORM AND LEGALITY  
OFFICE OF THE COUNTY ATTORNEY  
BY: Charles J. ...  
DATE: 23 October 2018