



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Fire Lane Establishment Order for Julius West Middle School	Executive Order No. 71-12	Subject Suffix
Originating Department Montgomery County Fire and Rescue Service	Department Number MCFRS 10-12	Effective Date 5/24/2012

Fire Lane Establishment Order

Pursuant to Section 22 - 33, Montgomery County Code, 1971, as amended, you are hereby notified that a Fire Lane has been established as described in this order. You are hereby ordered to post fire lane signs and paint curbs/pavement (painting optional) as identified below. When signs and paint work (painting optional) have been completed, this order will authorize the enforcement of this Fire Lane by appropriate police and fire officials. Compliance with this order must be achieved within 30 days of receipt.

LOCATION: Julius West Middle School
651 Great Falls Rd.

All areas where indicated by signs and paint.

- SIGNS - - (See attached diagram for location of sign placement)



\$250 FINE


FIRE LANE

Signs must be posted so that it is not possible to park a vehicle without being in sight of a sign. Signs may be no further apart than 100 feet

(Red letters on white background)

- PAINT - - (See attached diagram if painting).


Paint must be traffic yellow with lines of sufficient width to be readily identifiable/readable by motor vehicle operators.



Fire Chief, Montgomery County Fire and Rescue Service

AREA OF WORK - SEE PAGE 2
FOR SIGNAGE LOCATION

JULIUS WEST MIDDLE SCHOOL
651 GREAT FALLS ROAD
ROCKVILLE, MD. 20850

PAGE 1 OF 3_NEW SIGNAGE LOCATION






JULIUS WEST MIDDLE SCHOOL
 651 GREAT FALLS ROAD
 ROCKVILLE, MD. 20850

- Spaced evenly within the restriction (for straight curbs/zones). For example, if the parking restriction zone is 200' long, only one *double arrow* sign is required at a distance of 100' from the beginning of the restriction. If the restriction zone is 250' long, two *double arrow* signs are required; spaced evenly from each other and from the beginning/ending signs.
- Spaced so that at least one readable sign is visible in front of a parked vehicle from any point along the restriction (for curved curbs/zones and areas that may present visual obstacles).
- Set at an angle of no fewer than 30 degrees and no more than 45 degrees with the lane of traffic flow visible to approaching traffic.

Some areas may need additional fire lane signs. Review by the Fire Marshal's office will identify additional requirements.

Other Fire Lane Designations

The City of Rockville Office Fire Marshal's Office *may* require other designations such as curb painting in addition to signs. Per NFPA 1, *Fire Code*, Section 18.2.3.5, where required by the AHJ, approved signs or other approved notices shall be maintained to identify fire department access roads. The diagram below indicates the placement of these signs with the appropriate arrows.



JULIUS WEST MIDDLE SCHOOL
 651 GREAT FALLS ROAD
 ROCKVILLE, MD. 20850