coldcut systems

SAFER, CLEANER, MORE EFFICIENT

Electric car fire in an underground garage. Courtesy of Fire and Rescue Department of the Capital City of Prague. Computer translated from Czech language Nov 2023

coldcut systems

Fire and Rescue Department of the Capital City of Prague



Electric car fire in an underground garage

Incident Date: 4. 5. 2023 @ 23:56 Location: Praha 2, Bělehradská 299/132. Czech Republic

Original edit by: por. Mgr. Havrda Jan

Release Date: 25.5.2023

Updated: 28.5.2023

Contact: vds@hzspraha.cz

Translation by: M. Orman – Cold Cut Systems; Nov 2023

Contact: info@coldcutsystems.com

Approved for circulation by: Col. Jaromir Piesch Dec 2023




coldcut systems Incident Location





coldcut systems⁻ Incident Location





coldcut systems Incident Location






coldcut systems⁻ Incident Location






coldcut systems Incident Location





coldcut systems⁻ Incident Location





coldcut systems Jaguar i-Pace





coldcut systems Jaguar i-Pace - Technical Data



- SUV CONSTRUCTION: 4,682 x 1,895 x 1,565 mm, 2,133 kg
- DRIVE: Electric, driven axle: 4×4
- POWER: 294 kW, 400 hp, torque: 696 Nm
- BATTERY: 90 kWh (84.7 kWh usable capacity)
- CHARGING: Fast charging: 100 kW, onboard: 11 kW,

Thanks to three-phase charging, up to 53 km of range can be charged in one hour. From complete zero, the car's batteries are then recharged to their maximum capacity in less than 9 hours


coldcut systems Rescue Sheet





coldcut systems Battery Information





coldcut systems Incident Timeline

23:56

- reporting an event to the monitoring station, triggered sensor on the 2nd underground floor

23:57

departure of the Central Fire Station (CHS) Praha
Sokolsky unit (2x CAS20/2000/120-S1R/Cobra, 1x AZ30-M1Z 30m metre ladder)

00:01

- arrival of the CHS Praha - Sokolská unit at the scene of the intervention – it was returning from the intervention

00:02

- arrival of the CHS Praha Sokolská unit at the scene of the intervention – it was leaving the base

00:03

- the unit has contacted the permanent security of the building (they do not know what is going on)

- EPS (Electrical Fire Signal) survey on the 2nd underground floor with a negative result,

00:06

- Smoke was detected on the cameras on the 1st underground floor,

- A survey of these areas revealed white fine smoke coming from an electric car connected to the charging station and visible damage to the traction battery,





80:00


- explosion in the chassis part of the EV,
- immediate increase in smoke production,
- flaming burning,
- manual disconnection of the charging rectifier of the car from the electric networks,
- combat development, creation of a transport line 1 x B 75mm with a distributor and deployment of 2 x C42 mm,
- zero visibility,
- orientation possible only with thermal cameras,

00:09

- request for reinforcement units (VA-L2Z Incident Commnader, 2x CAS20/2000/120-S1R, 1x CAS30/11000/1000-S3LP, Chemical Service TA-L2CH/ODCH),

coldcut systems Situation Drawing







00:11

- effort to disconnect the building from electricity energy (electrical switchboard in 1st underground floor blocked by burning by vehicle), during the intervention the VZ decided not to disconnect the building from the electricity. Energy (motion elevators)

00:12

- installed smoke extractor from underground spaces - low effect

00:13

- 2nd grade PP announced,

00:15

- arrival of Incident Commander (VDS),

00:17

- arrival of reinforcement units at the site of the intervention Fire Station (HS) - Holešovice, HS - Strašnice),

00:18

- command of the intervention is taken over by VDS Lt. M.Sc. Jan HAVRDA,

00:20

- 3 x fire hose C-52 or 42mm, installed underground,

- COBRA high-pressure cutting equipment deployed,

00:23

- arrival TA-L2CH/ODCH Hazmat truck, CBRN lab and measuring equipment

- measurement and sampling started,

00:32

- preparation of a container for extinguishing EVs

$\overline{ }$

at HS - Holešovice,

00:35

- request for additional reinforcement units (2x CAS2/2000/120-M1Z, ODCH with PPLA (PPLA = truck with spare BA cylinders),

- after reaching a sufficient number of SaP, a survey was carried out in the above-ground floors

(previously Incident Commander was informed by security that the building was empty),

\bigcirc

00:45

- taking the elevators out of emergency mode in the EPS control panel,
- the decision of the General Assembly on the emergency transport of the elevator to the 4th level underground,
- sticking optical barriers = unblocking the elevator in this level,
- this ensures the removal of combustion fumes,
- replacement of exhaust fume extractors with overpressure ventilation for better smoke removal,

01:13

- flame burning extinguished,
- an electric car raised using the AKU HVZ to access the batteries,
- reinforcement units VYA-L1Z from CHS and KHE (container for the EV) + ANK13-S3 (truck for transporting containers) from HS - Holešovice,
- loading EVs onto transport carts,

coldcut systems CAS20/2000/120-S1R/Cobra





coldcut systems⁻ VYA-L1Z






coldcut systems Intervention process - ventilation



	View from Belgrade Road	A	
	, Oa		LNP
Half of the lift cabin Pokha vytahové kabiny The elevator is open Otevřené vytahové dveře			UP
The elevator is closed Zavlené výtahové dvele			Elevator Shafts Vjtahové šachty
			4.99


coldcut systems Intervention process - ventilation






coldcut systems⁻ Intervention Timeline















02:04

- the electric car was transported to the lift, the EV was checked repeatedly thermal camera


- Incident Commanders decision on the need to send four service members by lift (who were equipped with additional breathing apparatus (IDPs) and hand held fire extinguishers, (each on one corner of the vehicle),

- elevator controlled in an emergency from the elevator cabin,

- before the actual transport, another inspection of the vehicle with a thermal camera,

- use of overpasses to compensate for the height difference between the cabin elevator and floor 1st level underground,








02:10

- lift cabin open on the 1st floor level,
- using the VYA-L1Z electric car pulled out of the lift,
- electrolyte was leaking from the vehicle's battery all the time communication.







\bigcirc

02:32

- loading the electric car into the container using a hydraulic arm,
- its stabilization carried out,

02:35

- covering the leaked electrolyte with an absorbent,
- subsequent collection of the absorbent
- flushing the entire affected area with water
- negotiated a suitable place to place KHE (container) with EV with regard to the open event,

03:01

- departure of KHE to the SŽ campus,

03:28

- container folded and flooded with water 8 m3

11:12 a.m

- thermal camera check negative,

5:04 p.m

- measurement with a thermos camera measured up to 30 $^{\circ}\mathrm{C},$

5/5, 5/6, 5/7, 5/8

- sampling and their analysis,
- checking the condition of the electric car everything is stable,

12. 5.

- pulling the vehicle out of the container,
- loading for towing service,
- thermal camera check negative,
- the vehicle handed over to the owner's representative,



coldcut systems Incident Timeline



 \bigcirc

Position of the EV ni the container (KHE) before transport – secured the vehicle against movement.

coldcut systems Incident Vehicle with KHE (water container)



coldcut systems Findings from the intervention



- car fire detected by EPS (Electrical Fire Signal)
- a very large object with a complex orientation in the DZP. Operational cards in A4 format confusing and too small scale. DZP (fire plan) (46 pages, 1 floor one A4),
- the flaming fire did not occur until the arrival of the fire brigade,
- an electric car connected via an inverter to a 380 V socket, this was not a standard electric vehicle charger = it was possible to pull it out of the socket,
- it would be advisable to disconnect all chargers from a central point on that floor
- 17,000 litres of water was used in the attack on the attack line,
- \cdot 2,000 litres on the high-pressure COBRA fire extinguisher,

coldcut systems Findings from the intervention



- the COBRA fire extinguisher does not provide sufficient protection for the operator – it is necessary to have a water jet to cover firefighters from the start of COBRA deployment in the immediate proximity.
- Damaged protective suit of member who used COBRA.



coldcut systems Findings from the intervention



need to have all carts with swivel wheels and locking,


• the underground floor was full of dangerous fumes of smoke from vehicle batteries and contaminated firefighting water, we do not know what the responders absorb into their bodies by skin = think about taking samples from direct impacting bodies after the end of the intervention,

• 4 firefighter suits have been sent for analysis,

• one responding member suffered from nausea and pain between shifts head, the following shift was sent to the ÚVN (hospital in Prague) for examination (connection with was not proven by the intervention),

 insufficient load capacity of the carts, one cart has a load capacity of 510 kg and is useful vehicle weight 2266 kg,

• etching of the wheels on the auxiliary chassis,









• insufficient width of the lift cabin, unsuitable for transport use trolleys, emergency control of elevators from the cabin, impossibility to stop in the same level with the floor, damage to the transport trolley during attempts to drive up to the elevator, the need to purchase access ramps,


 absence of emergency control of the vehicle lift in the event of a fire – EPS stated elevators to the described mode, it was not possible to operate the elevator further, for example to create a ventilation hole or to transport a vehicle to the surface,


- absence of access ramp equipment for overcoming height differences,
- the elevator system was the only access route for cars to lower floors,



 inappropriate access ramps to the electrical container (KHE), ribbing and insufficient attachment of ramps,

• absence of anchoring eyes for anchoring the transported OA inside on the back side container,







 \cdot it is not possible to leave a container anywhere in the city, communication before the building was busy, including tram traffic,

• it is not possible to transport the vehicle in any other way – there is a constant flow of chemicals from the vehicle.

- corrosive substances escape when handling the vehicle,
- elevator shafts and the lower floor were flooded with contamination fire water,
- due to the fire of the traction batteries of the electric car, the premises filled with smoke very quickly.


• there is no device for fire ventilation and local performance. In the building, the installed ventilation is insufficient.



• at the time of the transfer it was an open event = it can be assumed different interests of interested parties (unclarified facts of the parties owner, car dealer, insurance company, the police and ambulance),

- the EV container must be guarded 24/7
- \cdot the risk of handling EV container drain valves,
- \cdot the risk of a person falling into a contaminated environment,
- $\boldsymbol{\cdot}$ restriction of access to the container with regard to security,
- dangerous character





coldcut systems Conclusions



• the Cobra high-pressure cutting device can be placed on the chassis of a pick-up truck with the option driving into underground garages,

• increase the number of KHE in the territory of HI. city of Prague, minimum condition 3 pcs.,

• equip the KHE construction with anchor points in the rear part to ensure transport EV,

 different design of handling carts under EV wheels, focus on load capacity, width and manoeuvrability, the ideal option is not to exceed the floor plan of the vehicle and possibility of filming all wheels + locking,

 equipped with approach ramps for overcoming height differences,

 equipped with crossing plates for overcoming unevenness and holes, • the wheels of handling carts must be made of durable materials acids and bases,

coldcut systems Conclusions



- ensuring sufficient protection of firefighters working with Cobra (cooling),
- \cdot equipping the units with hoods against the penetration of aerosols of harmful substances,
- the possibility of decontamination by undressing the member at the scene of the intervention a prevention of secondary contamination,
- decontamination of emergency footwear,
- detailed washing and decontamination of the emergency helmet,
- the wheels of handling carts must be made of durable materials acids and bases,